

SAMPLE MARKING LABEL

1. Performance Class and Performance Grade marking label:

Overall Rating Label

 Evaluated to/Évalué pour: AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-17	Manufacturer: Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367 Model No: EURC-7900SD-4MW-01 OXXX PDV4MW Sliding Patio Door Class LC – PG25 – Size tested: 4734 x 2426 mm (~186.4 x 95.5 in) – Type SD Positive/ Negative ASD Design Pressure (DP) = 1200 Pa Water Penetration Resistance Test Pressure = 220 Pa Canadian Air Infiltration/ Exfiltration = A2 Level
--	---

2. Energy Performance marking label:

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-01							
PVC frame; Double glazed system, Argon (90%) gap fill, ($\epsilon = 0.035$, S2), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
2	01*	LoE ² 270 on 3mm Clear ($\epsilon = 0.035$, S2)	Clear	Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	15.9 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.74		0.27		0.50			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				15			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use. Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-02							
PVC frame; Double glazed system, Argon (90%) gap fill, ($\epsilon = 0.02$, S2), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
2	02*	LoE ³ 366 on 3mm Clear ($\epsilon = 0.02$, S2)	Clear	Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	15.9 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.71		0.20		0.46			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				11			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use. Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-03							
PVC frame; Double glazed system, Argon (90%) gap fill, (ϵ = 0.035, S2, ϵ = 0.149, S4), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
2	03*	LoE ² 270 on 3mm Clear (ϵ = 0.035, S2) i89 on 3mm Clear (ϵ = 0.149, S4)	Clear	3mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	15.9 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.52		0.26		0.49			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				19			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use.
Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-04							
PVC frame; Double glazed system, Argon (90%) gap fill, ($\epsilon = 0.02$, S2, $\epsilon = 0.149$, S4), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
2	04*	LoE ³ 366 on 3mm Clear ($\epsilon = 0.02$, S2) i89 on 3mm Clear ($\epsilon = 0.149$, S4)	Clear	3mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	15.9 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.50		0.20		0.45			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				16			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use. Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-05 PVC frame; Double glazed system, Argon (90%) gap fill, (ϵ = 0.035, S2), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
2	05*	LoE ² 270 on 4mm Clear (ϵ = 0.035, S2)	Clear	4mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	14.3 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.72		0.26		0.49			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				14			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use.
Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-06 PVC frame; Double glazed system, Argon (90%) gap fill, (ϵ = 0.02, S2), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
2	06*	LoE ³ 366 on 4mm Clear (ϵ = 0.02, S2)	Clear	4mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	14.3 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.70		0.20		0.46			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				11			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use. Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-07							
PVC frame; Double glazed system, Argon (90%) gap fill, (ϵ = 0.035, S2, ϵ = 0.149, S4), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
2	07*	LoE ² 270 on 4mm Clear (ϵ = 0.035, S2) i89 on 4mm Clear (ϵ = 0.149, S4)	Clear	4mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	14.3 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.51		0.26		0.48			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				19			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use. Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-08							
PVC frame; Double glazed system, Argon (90%) gap fill, ($\epsilon = 0.02$, S2, $\epsilon = 0.149$, S4), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
2	08*	LoE ³ 366 on 4mm Clear ($\epsilon = 0.02$, S2) i89 on 4mm Clear ($\epsilon = 0.149$, S4)	Clear	4mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	14.3 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.49		0.20		0.45			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				16			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use.
Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-09							
PVC frame; Triple glazed system, Argon (90%) gap fill, ($\epsilon = 0.02$, S2, $\epsilon = 0.08$, S5), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	09*	LoE ³ 366 on 3mm Clear ($\epsilon = 0.02$, S2) LoE 180ESC on 3mm Clear ($\epsilon = 0.08$, S5)	Clear	3mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	11.1 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.24		0.18		0.41			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				20			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use. Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-10							
PVC frame; Triple glazed system, Argon (90%) gap fill, ($\epsilon = 0.02$, S2, $\epsilon = 0.08$, S4, $\epsilon = 0.149$, S6), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	10*	LoE ³ 366 on 3mm Clear ($\epsilon = 0.02$, S2) LoE 180ESC on 3mm Clear ($\epsilon = 0.08$, S4) i89 on 3mm Clear ($\epsilon = 0.149$, S6)	Clear	3mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	11.1 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.18		0.18		0.40			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				22			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use.
Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-11							
PVC frame; Triple glazed system, Argon (90%) gap fill, ($\epsilon = 0.02$, S2, $\epsilon = 0.149$, S6), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	11*	LoE ³ 366 on 3mm Clear ($\epsilon = 0.02$, S2) i89 on 3mm Clear ($\epsilon = 0.149$, S6)	Clear	3mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	11.1 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.32		0.18		0.41			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				19			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use. Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-12							
PVC frame; Triple glazed system, Argon (90%) gap fill, (ε = 0.02, S2), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	12*	LoE ³ 366 on 3mm Clear (ε = 0.02, S2)	Clear	3mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	11.1 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.44		0.19		0.42			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				16			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use. Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-13 PVC frame; Triple glazed system, Argon (90%) gap fill, (ϵ = 0.035, S2), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	13*	LoE ² 270 on 3mm Clear (ϵ = 0.035, S2)	Clear	3mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	11.1 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.45		0.25		0.45			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				20			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use. Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-14							
PVC frame; Triple glazed system, Argon (90%) gap fill, ($\epsilon = 0.035$, S2, $\epsilon = 0.149$, S6), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	14*	LoE ² 270 on 3mm Clear ($\epsilon = 0.035$, S2) i89 on 3mm Clear ($\epsilon = 0.149$, S6)	Clear	3mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	11.1 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.34		0.24		0.45			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				22			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use. Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-15 PVC frame; Triple glazed system, Argon (90%) gap fill, ($\epsilon = 0.035$, S2, $\epsilon = 0.035$, S5), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	15*	LoE ² 270 on 3mm Clear ($\epsilon = 0.035$, S2) LoE ² 270 on 3mm Clear ($\epsilon = 0.035$, S5)	Clear	3mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	11.1 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.23		0.23		0.39			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				23			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use. Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-16							
PVC frame; Triple glazed system, Argon (90%) gap fill, ($\epsilon = 0.035$, S2, $\epsilon = 0.035$, S4, $\epsilon = 0.149$, S6), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	16*	LoE ² 270 on 3mm Clear ($\epsilon = 0.035$, S2) LoE ² 270 on 3mm Clear ($\epsilon = 0.035$, S4) i89 on 5mm Clear ($\epsilon = 0.149$, S6)	Clear	3mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	11.1 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.16		0.20		0.38			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				23			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use. Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-17							
PVC frame; Triple glazed system, Argon (90%) gap fill, ($\epsilon = 0.02$, S2, $\epsilon = 0.08$, S5), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	17*	LoE ³ 366 on 4mm Clear ($\epsilon = 0.02$, S2) LoE 180ESC on 4mm Clear ($\epsilon = 0.08$, S5)	Clear	4mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	9.5 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.30		0.18		0.40			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				19			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use. Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-18							
PVC frame; Triple glazed system, Argon (90%) gap fill, ($\epsilon = 0.02$, S2, $\epsilon = 0.08$, S4, $\epsilon = 0.149$, S6), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	18*	LoE ³ 366 on 4mm Clear ($\epsilon = 0.02$, S2) LoE 180ESC on 4mm Clear ($\epsilon = 0.08$, S4) i89 on 4mm Clear ($\epsilon = 0.149$, S6)	Clear	4mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	9.5 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.23		0.17		0.40			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				20			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use.
Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-19							
PVC frame; Triple glazed system, Argon (90%) gap fill, ($\epsilon = 0.02$, S2, $\epsilon = 0.149$, S6), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	19*	LoE ³ 366 on 4mm Clear ($\epsilon = 0.02$, S2) i89 on 4mm Clear ($\epsilon = 0.149$, S6)	Clear	4mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	9.5 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.37		0.18		0.41			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				17			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use. Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-20							
PVC frame; Triple glazed system, Argon (90%) gap fill, ($\epsilon = 0.02$, S2), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	20*	LoE ³ 366 on 4mm Clear ($\epsilon = 0.02$, S2)	Clear	4mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	9.5 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.49		0.19		0.41			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				15			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use.
Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-21							
PVC frame; Triple glazed system, Argon (90%) gap fill, (ε = 0.035, S2), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	21*	LoE ² 270 on 4mm Clear (ε = 0.035, S2)	Clear	4mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	9.5 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.51		0.24		0.45			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				18			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use.
Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-22 PVC frame; Triple glazed system, Argon (90%) gap fill, ($\epsilon = 0.035$, S2, $\epsilon = 0.149$, S6), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	22*	LoE ² 270 on 4mm Clear ($\epsilon = 0.035$, S2) i89 on 4mm Clear ($\epsilon = 0.149$, S6)	Clear	4mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	9.5 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.38		0.24		0.44			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				21			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use. Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-23 PVC frame; Triple glazed system, Argon (90%) gap fill, ($\epsilon = 0.035$, S2, $\epsilon = 0.035$, S5), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	23*	LoE ² 270 on 4mm Clear ($\epsilon = 0.035$, S2) LoE ² 270 on 4mm Clear ($\epsilon = 0.035$, S5)	Clear	4mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	9.5 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.29		0.22		0.38			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				22			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use. Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).

Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367							
Energy Performance Results for OXXX PDV4MW Sliding Patio Door – EURC-7900SD-4MW-24							
PVC frame; Triple glazed system, Argon (90%) gap fill, ($\epsilon = 0.035$, S2, $\epsilon = 0.035$, S4, $\epsilon = 0.149$, S6), Spacer: Technoform Glass Insulation (TGI) Spacer Bar							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	24*	LoE ² 270 on 4mm Clear ($\epsilon = 0.035$, S2) LoE ² 270 on 4mm Clear ($\epsilon = 0.035$, S4) i89 on 4mm Clear ($\epsilon = 0.149$, S6)	Clear	4mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon (90%)	9.5 mm
ENERGY PERFORMANCE RATINGS							
U factor [W/m ² · K]		Solar Heat Gain Coefficient		Visible Transmittance			
1.22		0.20		0.37			
Air Leakage [L/s · m ²]				Energy Rating			
1.5				22			

Thermal performance and visual transmittance ratings certified to CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use. Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:19/CSA A440.3:19 & NFRC 100-2017. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

**NOTES:**

*Represents the Glazing Option according to Listing Report (can be only 1 - 24 at time of this report).