

Fenestration Certification Labels

Manufacturer: Polishinterior S.C.

Project No.: 21543
40.00.21543-9

1. Performance Class and Performance Grade marking example:

 Evaluated to/Évalué pour: CSA 101/1.S.2/A440-17	Manufacturer: Polishinterior S.C. Address: Nad Drwina 10 hala D9, 30-741 Krakow, Poland Email: maciek@polishinterior.com Tel: + 48 502 24 88 94 Model No: PI-RSL38TTF-IGXX Composite Window (Dual Action + Fixed) Class CW – PG30 – Size tested: 3048 x 2415mm (120.0 x 95.1 in) – Type DAW + FW Positive/ Negative ASD Design Pressure (DP) = 2160 Pa Water Penetration Resistance Test Pressure = 220 Pa Canadian Air Infiltration/ Exfiltration = A3 Level
--	--

Legend:

Class CW

PG30

PG2160 (SI)

Size tested 3048 x 2415 mm

Size tested 120.0 x 95.1 in

Dual Action Window or Type DAW

Fixed Window or Type FW

– Performance Class

– Performance Grade (IP)

– Performance Grade (SI)

– Maximum size tested (SI)

– Maximum size tested (IP)

– Product type

– Product type

Fenestration Certification Labels

Manufacturer: Polishinterior S.C.

Project No.: 21543
40.00.21543-9

2. Energy Performance marking example:

RSL38F - Fixed Window

Polishinterior S.C.

Address: Nad Drwina 10 hala D9, 30-741 Krakow, Poland

Email: maciek@polishinterior.com

Tel: + 48 502 24 88 94

Energy Performance Results for RSL38F Fixed Window – Series RSL38

Aluminum frame; Double glazed system; ClimaGuard Premium2 on 6mm Float Extra Clear, as per option stated below; Argon 90% gap filled; Spacer: Multitech G ALU PRO Warm Edge Spacer

No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
2	1*	ClimaGuard Premium2 on 6mm Extra Clear (Surface ε = 0.039)	Clear	6mm Float Extra Clear	Multitech G ALU PRO Warm Edge Spacer	Argon 90%	18 mm

ENERGY PERFORMANCE RATINGS

U factor [BTU/h·ft²·°F] 0.291	SOLAR HEAT GAIN COEFFICIENT 0.533	Visible Transmittance 0.702
Air Leakage [L/s · m²] 0.0		Energy Rating 35

Thermal performance and visual transmittance ratings certified to CSA A440.2:22 & NFRC 100-2020. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use.

Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:22 & NFRC 100-2020. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

NOTES:

*Represents the Glazing Option according to Listing Report (can be only 1 - 5 at time of this report).



Fenestration Certification Labels

Manufacturer: Polishinterior S.C.

Project No.: 21543
40.00.21543-9

Polishinterior S.C.

Address: Nad Drwina 10 hala D9, 30-741 Krakow, Poland

Email: maciek@polishinterior.com

Tel: + 48 502 24 88 94

Energy Performance Results for RSL38F Fixed Window – Series RSL38

Aluminum frame; Triple glazed system; ClimaGuard Premium2 on 4mm Float Extra Clear, as per option stated below; Argon 90% gap filled; Spacer: Multitech G ALU PRO Warm Edge Spacer

No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	2*	ClimaGuard Premium2 on 4mm Extra Clear (Surface $\varepsilon = 0.039$)	Clear	4mm Float Extra Clear	Multitech G ALU PRO Warm Edge Spacer	Argon 90%	18 mm

ENERGY PERFORMANCE RATINGS

U-factor [BTU/h-ft ² -°F]	SOLAR HEAT GAIN COEFFICIENT	Visible Transmittance
0.169	0.440	0.637
Air Leakage [L/s · m ²]		Energy Rating
0.0		44

Thermal performance and visual transmittance ratings certified to CSA A440.2:22 & NFRC 100-2020. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use.

Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:22 & NFRC 100-2020. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

NOTES:

*Represents the Glazing Option according to Listing Report (can be only 1 - 5 at time of this report).



Fenestration Certification Labels

Manufacturer: Polishinterior S.C.

Project No.: 21543
40.00.21543-9

Polishinterior S.C.

Address: Nad Drwina 10 hala D9, 30-741 Krakow, Poland

Email: maciek@polishinterior.com

Tel: + 48 502 24 88 94

Energy Performance Results for RSL38F Fixed Window – Series RSL38

Aluminum frame; Triple glazed system; SunGuard SN70S HT on 4mm Extra Clear, as per option stated below;
Argon 90% gap filled; Spacer: Multitech G ALU PRO Warm Edge Spacer

No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	4*	SunGuard SN70S HT on 4mm Extra Clear (Surface $\varepsilon = 0.027$)	Clear	4mm Float Extra Clear	Multitech G ALU PRO Warm Edge Spacer	Argon 90%	18 mm

ENERGY PERFORMANCE RATINGS

U-factor [BTU/h-ft ² -°F]	SOLAR HEAT GAIN COEFFICIENT	Visible Transmittance
0.166	0.266	0.485
Air Leakage [L/s · m ²]		Energy Rating
0.0		35

Thermal performance and visual transmittance ratings certified to CSA A440.2:22 & NFRC 100-2020. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use.

Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:22 & NFRC 100-2020. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

NOTES:

*Represents the Glazing Option according to Listing Report (can be only 1 - 5 at time of this report).



Fenestration Certification Labels

Manufacturer: Polishinterior S.C.

Project No.: 21543
40.00.21543-9

Polishinterior S.C.

Address: Nad Drwina 10 hala D9, 30-741 Krakow, Poland

Email: maciek@polishinterior.com

Tel: + 48 502 24 88 94

Energy Performance Results for RSL38F Fixed Window – Series RSL38

Aluminum frame; Triple glazed system; SunGuard SN70S HT on 6mm Extra Clear, as per option stated below;
Argon 90% gap filled; Spacer: Multitech G ALU PRO Warm Edge Spacer

No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	5*	SunGuard SN70S HT on 6mm Extra Clear (Surface $\varepsilon = 0.027$)	Clear	6mm Float Extra Clear	Multitech G ALU PRO Warm Edge Spacer	Argon 90%	16 mm

ENERGY PERFORMANCE RATINGS

U-factor [BTU/h-ft ² -°F]	SOLAR HEAT GAIN COEFFICIENT	Visible Transmittance
0.164	0.263	0.476
Air Leakage [L/s · m ²]		Energy Rating
0.0		35

Thermal performance and visual transmittance ratings certified to CSA A440.2:22 & NFRC 100-2020. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use.

Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:22 & NFRC 100-2020. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

NOTES:

*Represents the Glazing Option according to Listing Report (can be only 1 - 5 at time of this report).



Fenestration Certification Labels

Manufacturer: Polishinterior S.C.

Project No.: 21543
40.00.21543-9

RSL38TT – Dual Action Window

Polishinterior S.C. Address: Nad Drwina 10 hala D9, 30-741 Krakow, Poland Email: maciek@polishinterior.com Tel: + 48 502 24 88 94							
Energy Performance Results for RSL38TT Dual Action Window– Series RSL38 Aluminum frame; Double glazed system; ClimaGuard Premium2 on 6mm Float Extra Clear, as per option stated below; Argon 90% gap filled; Spacer: Multitech G ALU PRO Warm Edge Spacer							
No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
2	1*	ClimaGuard Premium2 on 6mm Extra Clear (Surface ε = 0.039)	Clear	6mm Float Extra Clear	Multitech G ALU PRO Warm Edge Spacer	Argon 90%	18 mm
ENERGY PERFORMANCE RATINGS							
U factor [BTU/h-ft ² -°F]		SOLAR HEAT GAIN COEFFICIENT		Visible Transmittance			
0.315		0.479		0.628			
Air Leakage [L/s · m ²]				Energy Rating			
0.0				29			

Thermal performance and visual transmittance ratings certified to CSA A440.2:22 & NFRC 100-2020. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use.

Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:22 & NFRC 100-2020. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

NOTES:

*Represents the Glazing Option according to Listing Report (can be only 1 - 5 at time of this report).



Fenestration Certification Labels

Manufacturer: Polishinterior S.C.

Project No.: 21543
40.00.21543-9

Polishinterior S.C.

Address: Nad Drwina 10 hala D9, 30-741 Krakow, Poland

Email: maciek@polishinterior.com

Tel: + 48 502 24 88 94

Energy Performance Results for RSL38TT Dual Action Window– Series RSL38

Aluminum frame; Triple glazed system; ClimaGuard Premium2 on 4mm Float Extra Clear, as per option stated below; Argon 90% gap filled; Spacer: Multitech G ALU PRO Warm Edge Spacer

No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	2*	ClimaGuard Premium2 on 4mm Extra Clear (Surface $\varepsilon = 0.039$)	Clear	4mm Float Extra Clear	Multitech G ALU PRO Warm Edge Spacer	Argon 90%	18 mm

ENERGY PERFORMANCE RATINGS

U-factor [BTU/h-ft ² -°F]	SOLAR HEAT GAIN COEFFICIENT	Visible Transmittance
0.205	0.396	0.570
Air Leakage [L/s · m ²]		Energy Rating
0.0		37

Thermal performance and visual transmittance ratings certified to CSA A440.2:22 & NFRC 100-2020. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use.

Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:22 & NFRC 100-2020. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

NOTES:

*Represents the Glazing Option according to Listing Report (can be only 1 - 5 at time of this report).



Fenestration Certification Labels

Manufacturer: Polishinterior S.C.

Project No.: 21543
40.00.21543-9

Polishinterior S.C.

Address: Nad Drwina 10 hala D9, 30-741 Krakow, Poland

Email: maciek@polishinterior.com

Tel: + 48 502 24 88 94

Energy Performance Results for RSL38TT Dual Action Window– Series RSL38

Aluminum frame; Triple glazed system; ClimaGuard Premium2 on 6mm Float Extra Clear, as per option stated below; Argon 90% gap filled; Spacer: Multitech G ALU PRO Warm Edge Spacer

No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	3*	ClimaGuard Premium2 on 6mm Extra Clear (Surface $\varepsilon = 0.039$)	Clear	6mm Float Extra Clear	Multitech G ALU PRO Warm Edge Spacer	Argon 90%	16 mm

ENERGY PERFORMANCE RATINGS

U-factor [BTU/h-ft ² -°F]	SOLAR HEAT GAIN COEFFICIENT	Visible Transmittance
0.204	0.386	0.561
Air Leakage [L/s · m ²]		Energy Rating
0.0		37

Thermal performance and visual transmittance ratings certified to CSA A440.2:22 & NFRC 100-2020. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use.

Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:22 & NFRC 100-2020. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

NOTES:

*Represents the Glazing Option according to Listing Report (can be only 1 - 5 at time of this report).



Fenestration Certification Labels

Manufacturer: Polishinterior S.C.

Project No.: 21543
40.00.21543-9

Polishinterior S.C.

Address: Nad Drwina 10 hala D9, 30-741 Krakow, Poland

Email: maciek@polishinterior.com

Tel: + 48 502 24 88 94

Energy Performance Results for RSL38TT Dual Action Window– Series RSL38

Aluminum frame; Triple glazed system; SunGuard SN70S HT on 4mm Extra Clear, as per option stated below;
Argon 90% gap filled; Spacer: Multitech G ALU PRO Warm Edge Spacer

No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	4*	SunGuard SN70S HT on 4mm Extra Clear (Surface $\varepsilon = 0.027$)	Clear	4mm Float Extra Clear	Multitech G ALU PRO Warm Edge Spacer	Argon 90%	18 mm

ENERGY PERFORMANCE RATINGS

U-factor [BTU/h-ft ² -°F]	SOLAR HEAT GAIN COEFFICIENT	Visible Transmittance
0.203	0.240	0.434
Air Leakage [L/s · m ²]		Energy Rating
0.0		29

Thermal performance and visual transmittance ratings certified to CSA A440.2:22 & NFRC 100-2020. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use.

Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:22 & NFRC 100-2020. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

NOTES:

*Represents the Glazing Option according to Listing Report (can be only 1 - 5 at time of this report).



Fenestration Certification Labels

Manufacturer: Polishinterior S.C.

Project No.: 21543
40.00.21543-9

Polishinterior S.C.

Address: Nad Drwina 10 hala D9, 30-741 Krakow, Poland

Email: maciek@polishinterior.com

Tel: + 48 502 24 88 94

Energy Performance Results for RSL38TT Dual Action Window– Series RSL38

Aluminum frame; Triple glazed system; SunGuard SN70S HT on 6mm Extra Clear, as per option stated below;
Argon 90% gap filled; Spacer: Multitech G ALU PRO Warm Edge Spacer

No. of glazing layers	Glazing option no.	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	5*	SunGuard SN70S HT on 6mm Extra Clear (Surface $\varepsilon = 0.027$)	Clear	6mm Float Extra Clear	Multitech G ALU PRO Warm Edge Spacer	Argon 90%	16 mm

ENERGY PERFORMANCE RATINGS

U-factor [BTU/h-ft ² -°F]	SOLAR HEAT GAIN COEFFICIENT	Visible Transmittance
0.201	0.237	0.426
Air Leakage [L/s · m ²]		Energy Rating
0.0		29

Thermal performance and visual transmittance ratings certified to CSA A440.2:22 & NFRC 100-2020. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use.

Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2:22 & NFRC 100-2020. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

NOTES:

*Represents the Glazing Option according to Listing Report (can be only 1 - 5 at time of this report).

