

SAMPLE MARKING LABEL

1. Performance Class and Performance Grade marking label:

Overall Rating Label

 Evaluated to/Évalué pour: CSA 101/I.S.2/A440-17 CSA A440S1-17	Manufacturer: Euroclad Windows and Doors Address: 2490 Ross Road, West Kelowna, BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367 Model No: EURC-WSAW-5,272(2)-11AR95TG-5,CL Awning Window Class CW – PG30 – Size tested: 3052 x 1564 mm (~120 x 62 in) – Type AP Positive/ Negative ASD Design Pressure (DP) = 1440 Pa Water Penetration Resistance Test Pressure = 720 Pa Canadian Air Infiltration/ Exfiltration = A3 Level
--	---

2. Energy Performance marking label:

Euroclad Windows and Doors. Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada Email: steve@eurocladsystems.com, Tel: (250) 769-0367						
Energy Performance Results for Wood Server Awning Window Model Code: EURC-WSAW-5,272(2)-11AR95TG-5,CL Wooden frame; Double glazed system, Argon 95% gap fill, Low E ($\epsilon=0.042$, S2), Spacer: Technoform Glass Insulation space bar (TG)						
No. of glazing layers	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
2	LoE 272 on 5mm Cardinal glass ($\epsilon = 0.042$, S2)	Clear	5mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon 95%	11.35 mm
ENERGY PERFORMANCE RATINGS						
U factor [W/m ² · K]	SOLAR HEAT GAIN COEFFICIENT	Visible Transmittance				
1.80	0.23	0.37				
Air Leakage [L/s · m²]			Energy Rating			
0.3			13			

Thermal performance and visual transmittance ratings certified to CSA A440.2-14. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use.

Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2-14. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.



Euroclad Windows and Doors.

Address: 2490 Ross Road, West Kelowna BC V1Z 1M1, Canada

Email: steve@eurocladsystems.com, Tel: (250) 769-0367**Energy Performance Results for Wood Server Awning Window**
Model Code: EURC-WSAW-5,272(2)-7AR95TG-5, CL-7AR95TG-5, CLWooden frame; Triple glazed system, Argon 95% gap fill, Low E ($\epsilon=0.042$, S2), Spacer: Technoform
Glass Insulation space bar (TG)

No. of glazing layers	Glass surface emissivity with Low-E coating	Tint description	Glass type(s)	Spacer type(s)	Gap fill(s)	Gap width(s)
3	LoE 272 on 5mm Cardinal glass ($\epsilon = 0.042$, S2)	Clear	5mm Clear	Technoform Glass Insulation (TGI) Spacer Bar	Argon 95%	6.75 mm

ENERGY PERFORMANCE RATINGS

U factor [W/m ² · K]	SOLAR HEAT GAIN COEFFICIENT	Visible Transmittance
1.76	0.21	0.34
Air Leakage [L/s · m ²]		Energy Rating
0.3		13

Thermal performance and visual transmittance ratings certified to CSA A440.2-14. Ratings are determined for fixed set of environmental conditions and a specific product. LabTest Certification Inc. agency does not recommend or warrant product for any specific use.

Les taux de performance thermique et de transmission visuelle certifiées selon la norme CSA A440.2-14. L'évaluation est déterminée pour un ensemble fixe de conditions environnementales et un produit spécifique. LabTest Certification Inc. ne recommande pas et ne recommande aucun produit pour une utilisation particulière.

